

## HKR Insulated ½ inch Tubular Socket Wrench up to 1 kV AC / 1,5 kV DC

### PHOTOS



Product compliant with the requirements of EN IEC 60900:2018 standards

Product code	Size	Weight	Length
A111.1910	10 mm	110 g	95 mm
A111.1913	13 mm	130 g	95 mm
A111.1914	14 mm	125 g	95 mm
A111.1917	17 mm	140 g	95 mm
A111.1919	19 mm	160 g	95 mm
A111.1922	22 mm	180 g	95 mm

Length and weight tolerances are  $\pm 2\%$ . Due to continuous product development, product appearance may differ slightly from that shown in the photos.

### CHARACTERISTICS

Insulated tool, made of CrV steel with 12-point working head. ½ inch square socket. Insulation made of plastisol (PVC), dipping technology. The tool's insulation is double-layered in contrasting colors, white and orange. In the upper part, on a section of about 15 mm, single-layer orange insulation. Thickness of each layer at least 1 mm. It has an insert to prevent the nut from falling in deeper. Possibility to produce sockets in other sizes.

### APPLICATION

Sockets are used for live work up to 1 000 V AC or up to 1 500 V DC for assembly work in switchgear equipment. Especially when loosening and tightening the screws that secure the fuse bases. Works with bar drives, torque wrench, ratchet drives and extensions and other tools that have ½ inch square

## HKR Insulated ½ inch Tubular Socket Wrench up to 1 kV AC / 1,5 kV DC

### STORAGE AND MAINTENANCE

Store the socket in a bag or toolbox separate from other tools to avoid mechanical damage. Store the socket in dry areas away from heat sources, in a non-aggressive chemical atmosphere. Protect from sunlight.

The socket should be cleaned after each use. Use a dry cloth for cleaning. If the drive is very dirty, clean it with a cloth dampened in water with a mild detergent or cloth dampened with ASOREL and dry thoroughly.

### EXAMINATION

A visual inspection of the socket should be made before each operation. Carry out a periodic inspection, also by visual inspection, once a year.

Visual inspection includes checking:

- no visible defects in the socket,
- no visible damage to the socket insulation,
- legibility and completeness of the socket marking.

Socket that is damaged, heavily worn (mechanical damage to the insulation) or dirty must not be used for live work. Damage resulting in the exposure of the inner (white) insulation layer eliminates the possibility of further use of the tool in live work. In case of moisture, the socket should be thoroughly dried before use.

### CAUTION!

In case of doubt, after the visual inspection, the tool should be re-tested for electric strength or withdrawn from use in live work.

### FREQUENCY TESTS

For check and periodic inspection to be carried out in according to table.

	CHECK	PERIODIC INSPECITON
Who	Manager of team	Supervision
When	Before use	Once a year
How	Visually	Visually

*\*Unless instructions say otherwise*

**A111.19xx**

**TECHNICAL SHEET**  
2022.07

**hubix**  
SAFETY IN POWER

**HKR Insulated ½ inch Tubular Socket Wrench  
up to 1 kV AC / 1,5 kV DC**

---

**hubix**

Hubix sp. z o.o. | Główna 43 St. | Huta Żabiowska | 96-321 Żabia Wola | Poland  
hubix@hubix.pl | www.hubix.pl | t. +48 46 857 84 40 | VAT no. PL5291803171