

A112.0401

TECHNICAL SHEET
2022.10

hubix

SAFETY IN POWER

**H028-P Insulating "S" Type Cover Installer
up to 1 kV AC / 1,5 kV DC**

PHOTOS



Product compliant with the requirements of EN IEC 60900:2018 standard.

The distance between the arms: 14 mm
Length: 175 mm
Weight: 150 g

Length and weight tolerances are $\pm 2\%$. Due to continuous product development, product appearance may differ slightly from that shown in the photos.

CHARACTERISTICS

Tool made entirely of insulating material, red fiberglass reinforced polyamide. The handle ends with two parallel arms. The distance between the arms is 14 mm.

APPLICATION

The installers are used for live work up to 1 000 V AC or up to 1 500 V DC. The tool is used to put "S" type insulation covers on bare wires of overhead lines. The distance between the arms enables the installation of "S" type covers for wires with a cross-section of 16 - 95 mm².

STORAGE AND MAINTENANCE

Store the tool in a bag or toolbox separate from other tools to avoid mechanical damage. Store the tool in dry areas away from heat sources, in a non-aggressive chemical atmosphere. Protect from sunlight.

The tool should be cleaned after each use. Use a dry cloth for cleaning. If the tool is very dirty, clean it with a cloth dampened in water with a mild detergent or cloth dampened with ASOREL and dry thoroughly.

**H028-P Insulating "S" Type Cover Installer
up to 1 kV AC / 1,5 kV DC****EXAMINATION**

A visual inspection of the tool should be made before each operation. Carry out a periodic inspection, also by visual inspection, once a year.

Visual inspection includes checking:

- no visible defects in the tool,
- legibility and completeness of the tool marking.

The tool that is damaged, heavily worn (mechanical damage) or dirty must not be used for live work. In case of moisture, the tool should be thoroughly dried before use.

CAUTION!

In case of doubt, after the visual inspection, the tool should be withdrawn from use in live work.

FREQUENCY TESTS

For check and periodic inspection to be carried out in according to table.

	CHECK	PERIODIC INSPECITON
Who	Manager of team	Supervision
When	Before use	Once a year
How	Visually (visual inspection)	Visually (visual inspection)

**Unless instructions say otherwise*