

TB25 Conductor cleaning brush**PHOTOS**

Product compliant with the requirements of PN- EN 60832-2:2010 standard.

Length: 58 mm
Weight: 90 g

Length and weight tolerances are $\pm 2\%$. Due to continuous product development, product appearance may differ slightly from that shown in the photos.

CHARACTERISTICS

A metal brush with steel bristles, equipped with a splined end fitting designed for mounting on a universal insulating stick using a head fitting manufactured in accordance with the EN 60832-2:2010 standard

APPLICATION

The brush, mounted on insulating or telescopic sticks, is used to clean overhead line conductors from corrosion and contamination prior to the installation of a clamp or shunt, during live working on overhead lines up to 1000V AC and 1500V DC.

STORAGE AND MAINTENANCE

The brush must be stored in a manner that protects it against mechanical damage. It should be kept in dry rooms, away from heat sources, and in a chemically non-aggressive atmosphere. Protect from direct sunlight. The brush should be cleaned after each use. Use a dry cloth for cleaning. In the event of heavy soiling, clean the tool with isopropyl alcohol and dry thoroughly.

EXAMINATION

A visual inspection of the brush must be performed prior to each commencement of work. A periodic inspection, also consisting of a visual check, should be carried out once a year. The visual inspection includes checking for:

- the absence of visible tool defects, in particular regarding the splined fitting and bristles,
- proper attachment to the stick,
- the legibility and completeness of the markings.

A brush that is damaged, heavily worn (mechanical damage to the splined fitting or bristles), or dirty must not be used for live working. If it becomes damp, the brush must be thoroughly dried before use.

CAUTION! In case of any doubt following the visual inspection, the tool must be withdrawn from service.

TB25 Conductor cleaning brush

FREQUENCY TESTS

	CHECK	PERIODIC INSPECITON
Who	Manager of team	Supervision
When	Before use	Once a year
How	Visually (visual inspection)	Visually (visual inspection)

For check and periodic inspection to be carried out in according to table.

**Unless instructions say otherwise*