

H039 Insulating Wedge, up to 1 kV AC / 1,5 kV DC**PHOTOS**

Product compliant with the requirements of EN IEC 60900:2018 standard.

Length of the rope: 1 m
Total weight: 130 g

Length and weight tolerances are $\pm 2\%$. Due to continuous product development, product appearance may differ slightly from that shown in the photos.

CHARACTERISTICS

Wedges made entirely of insulating material, red fiberglass reinforced polyamide. The tool was manufactured using the injection molding process. The wedges are connected by a propylene rope with a diameter of 4 mm and a length of 1 m.

APPLICATION

The wedge is used for live work up to 1 000 V AC or up to 1 500 V DC. The wedges are designed for separating a single wire of the conductor from the cable harness type AsXS_n on overhead lines.

STORAGE AND MAINTENANCE

Store the wedge in a bag or toolbox separate from other tools to avoid mechanical damage. Store the wedge in dry areas away from heat sources, in a non-aggressive chemical atmosphere. Protect from sunlight.

The wedge should be cleaned after each use. Use a dry cloth for cleaning. If the wedge is very dirty, clean it with a cloth dampened in water with a mild detergent or cloth dampened with ASOREL and dry thoroughly.

EXAMINATION

Before use, each socket should be visually inspected by the user. An annual visual inspection by a suitably trained person is recommended to determine the suitability of the tool for further service.

H039 Insulating Wedge, up to 1 kV AC / 1,5 kV DC

Visual inspection includes checking:

- no visible defects in the wedge,
- no visible defects of the rope
- legibility and completeness of the wedge marking.

Wedges that is damaged (crack), heavily worn or dirty must not be used for live work. In case of moisture, the wedge should be thoroughly dried before use.

CAUTION!

In case of doubt, after the visual inspection, the tool should be withdrawn from use in live work.

FREQUENCY TESTS

For check and periodic inspection to be carried out in according to table.

	CHECK	PERIODIC INSPECITON
Who	Manager of team	Supervision
When	Before use	Once a year
How	Visually (visual inspection)	Visually (visual inspection)

**Unless instructions say otherwise*